

**Series SAFE TROVIS 3793**  
**TROVIS SAFE 3793 Electropneumatic Positioner**  
with HART® communication



Device		Integration Revision	Indicating and operating modules							
Model Index	Firmware	HART Device Rev	TROVIS-VIEW	Emerson AMS <sup>4</sup>	Siemens PDM <sup>3</sup>	DTM (FDT 1.2)	Yokogawa PRM	Honeywell Experion	Field Communicator 475	FCG DD
00	1.00.03-1.00.99	1	≥ 4.66	≥10.0	≥9.0	≥ 1.1.0	✓	✓	✓	✓

<sup>3</sup> Device is subsequently added to PDM using the "device install" / "manage device catalog" function (available at [www.samsongroup.com](http://www.samsongroup.com))

<sup>4</sup> Device is subsequently added to AMS using the "install kit" function (available at [www.samsongroup.com](http://www.samsongroup.com))